



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

DMB

January 17, 1984


Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58
Docket Nos. 50-315

Dear Mr. Keppler:

Pursuant to the requirements of Appendix B, Part II, Nonradiological, Environmental Protection Plan, Section 3.2, a copy of the report to the Michigan Water Resources Commission notifying them of the failure to take the Steam Generator Blowdown Flash Tank sampling for pH and total suspended solids on December 18, 1983, is attached. This report is required by Amendment No. 54 to Facility Operating License No. DPR-58 and Amendment No. 40 to Facility Operating License No. DPR-74 dated May 6, 1982.

Sincerely,


W.G. Smith, Jr.
Plant Manager

/bab

Attachment

cc: John E. Dolan
M.P. Alexich
R.F. Kroeger
H. Bruggcr
E.R. Swanson, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan

INPO
Dir., IE (20 copies)
Dir., MIPC (2 copies)
PNSRC
J.F. Stietzel
E.L. Townley
R.O. Bruggee, EPRI
H.R. Denton

8401240063 840117
PDR ADDCK 05000315
S PDR


JAN 19 1984

IE22
1/1

RECEIVED

JAN 10 1984

Technical Dept.



INDIANA & MICHIGAN ELECTRIC COMPANY

ONE SUMMIT SQUARE, P. O. BOX 60, FORT WAYNE IN. 46801

Telephone: (219) 425-2111

January 6, 1984

RICHARD C. MENGE

Vice President

Mr. Paul D. Zugger
Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building
Box 30026
Lansing, Michigan 48909

Re: Donald C. Cook Nuclear Plant
NPDES Permit #MI 0005827
Outfall 001

Dear Mr. Zugger:

During preparation of the monthly monitoring report required by the NPDES permit, it was discovered that sampling for pH and Total Suspended Solids from the Unit #1 Steam Generator Blowdown Flash Tank was inadvertently missed on December 18, 1983.

The Unit #1 Reactor, which had been out of service since November 22, 1983, became critical at 1057 hours (12/18/83) and was in the early stage of startup.

Very truly yours,

R. C. Menge
Vice President

RCM/be

cc: W. G. Smith, Jr.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

R. C. Menge

bc: R. W. Jurgensen
T. A. Kriesel
J. A. Wojcik
R. W. Reeves/C. E. Hawk
J. P. White
R. E. Zahler