



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

January 20, 1984

Mr. J. G. Keppler, Regional Administrator
Office of Inspection and Enforcement,
Region III
U. S. NUCLEAR REGULATORY COMMISSION
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:


DOCKET NOS. 50-266 AND 50-301
RESPONSE TO IE BULLETIN NO. 83-08
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

In response to IE Bulletin No. 83-08, "Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications Other Than the Reactor Trip System", dated December 28, 1983, Wisconsin Electric has reviewed the necessary technical information for all of its breakers with safety-related applications at its Point Beach Nuclear Plant. We have concluded that there are no circuit breakers with an undervoltage trip attachment in use in safety-related applications other than the reactor trip system. Accordingly, we are providing this negative response to the subject bulletin.

To assist the NRC in evaluating the cost of this bulletin on the utility, the total staff time to perform the requested review and prepare the requested documentation was approximately ten hours.

Very truly yours,


8401240072 840120
PDR ADOCK 05000266
Q PDR


Vice President-Nuclear Power

C. W. Fay

Copies to NRC Resident Inspector
NRC Document Control Desk, Washington (w/original)

Subscribed and sworn to before me
this 20th day of January 1984.


Notary Public, State of Wisconsin

My Commission expires July 1, 1984.

IEI
110