

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 2 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 20 26 LICENSE TYPE 30 37 CAT 38

CON'T

REPORT SOURCE: 01 L 6 0 5 0 1 0 0 3 1 1 6 7 1 2 2 0 8 3 S 0 1 1 7 8 4 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 | DURING A SURVEILLANCE TEST ON STEAM GENERATOR 1 PROTECTION CHANNEL SET I, IT WAS FOUND

013 | THAT THE OUTPUT FROM BISTABLE 2FB-512B (STEAM FLOW GREATER THAN REFERENCE STEAM FLOW)

014 | FLUCTUATED AT BOTH THE TRIP AND RESET POINTS. THE BISTABLE WAS REPLACED. THIS EVENT

015 | WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION 3.3.1.1 TABLE 3.3-1

016 | ITEM 15. THE ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.

017 |

018 |

7 8 9

SYSTEM CODE 9 10		CAUSE CODE 11 12		CAUSE SUBCODE 13 14		COMPONENT CODE 15 16		COMP SUBCODE 17 18		VALVE SUBCODE 19 20	
I A		E		E		I N I S T R U		S		Z	
17		EVENT YEAR 21 22		SEQUENTIAL REPORT NO. 23 24		OCCURRENCE CODE 25 26		REPORT TYPE 27 28		REVISION NO. 29 30	
LE/RO REPORT NUMBER		8 3		1 2 3		0 3		L		0	
ACTION TAKEN 33 34		FUTURE ACTION 35 36		EFFECT ON PLANT 37 38		SHUTDOWN METHOD 39 40		HOURS 41 42		ATTACHMENT SUBMITTED 43 44	
A		Z		Z		Z		0 0 0 0		N	
13 19		20		21		22		23		24	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 45 46		NPRD-4 FORM 4 47 48		PRIME COMP. SUPPLIER 49 50		COMPONENT MANUFACTURER 51 52		43		44	
F 1 8 10											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

110 THE REPLACEMENT BISTABLE WAS CALIBRATED, VERIFIED TO BE OPERATING CORRECTLY AND RETURNED
111 TO SERVICE.
112
113
114

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	35	1	0	0	23	NA	B
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA			
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	10	10	37	Z	38	NA	
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	10	10	40			NA	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	47					NA	
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	44					NA	

NRC USE ONLY

NAME OF ORG. PREPARED:

R. A. PALMER

(616)465-5901