



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 9, 1984

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File: 0260/L-835.0  
Special Report 83-113/0 - Fire  
Rated Door 1A201 Inoperable  
AECM-84/0025

On December 2, 1983, fire rated door 1A201 to the Turbine Building was reported to be inoperable. The latching mechanism on the door was damaged as the result of heavy use.

Fire watches were established in accordance with Technical Specification 3.7.7 until the door was restored on December 13, 1983.

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,



L. F. Dale  
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8401240385 840109  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

ORIGINAL COPY

Jan 22

|||

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0025

Page 2

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555