

**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4			5
7	8	9						14						25						30						57		58	
		LICENSEE CODE						LICENSE NUMBER						LICENSE TYPE						CAT									

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	L	6	0	5	0	0	0	3	3	3	7	0	1	2	0	8	3	8	0	2	0	3	8	3	9															
		60	61	DOCKET NUMBER										68	69	EVENT DATE										74	75	REPORT DATE										80			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While the plant was shutdown, "A" laundry drain tank was placed in a recirc. line-up  
0 3 | with the discharge line-up still available. This resulted in an un-planned release  
0 4 | of 130 gallons of laundry effluent prior to sample. Environmental Tech. Spec. 2.3.  
0 5 | A.2 requires a sample prior to batch release. Because the effluent monitor was oper-  
0 6 | able during this release, the release was properly monitored. This event posed no  
0 7 | threat to public health or safety.

7 8 9 80

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

7 8 9 10 11 12 13 14 15 16 17 18 19 20

0 8 0 9 M A A B Z Z Z Z Z Z Z Z Z Z

(17) LER/RO REPORT NUMBER	[EVENT YEAR 8   3 21    22]	[ — 23]	SEQUENTIAL REPORT NO. 0   0   5 24    25    26	[ / 27]	OCCURRENCE CODE 0   3 28    29	REPORT TYPE L 30	[ — 31]	NO. 0 32
ACTION TAKEN G   H 13    14    15    16	FUTURE ACTION H 17	EFFECT ON PLANT Z 18    19	SHUTDOWN METHOD Z 20    21	HOURS 0   0   0   0 22    23    24    25	ATTACHMENT SUBMITTED N 26    27	NPRD-4 FORM SUB. N 28    29	PRIME COMP. SUPPLIER Z 30    31	COMPONENT MANUFACTURER 7   9   9   9 32    33    34    35

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (4)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (1)

1	0	When the operator noticed a decrease in "A" laundry tank level, the pump was se-
1	1	cured and the discharge valve was shut. This valve is common to both tanks. The
1	2	operator involved was counselled on adhering to procedures. Procedure F-OP-49 will
1	3	be revised to caution operators. In addition, a modification has been submitted to
1	4	split the line-up of these two tanks.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 G 000 NA A Operator Observation

ACTIVITY CONTENT  
RELEASED RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
1 6 L 33 M 34 20.3 Microcuries Total Laundry Drain Tank to Discharge Canal

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
1	7	00	NA

PERSONNEL INJURIES	
NUMBER	DESCRIPTION (41)
1 3	0 0 0 (40) NA

		LOSS OF OR DAMAGE TO FACILITY		
		TYPE	DESCRIPTION	
1	9	Z	(42) NA	8303230481 830303

8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PUBLICITY  
ISSUED DESCRIPTION (45)  
2 0 N 44  
PDR ADOCK 05000333  
S PDR  
NRC USE ONLY

NAME OF PREPARER Roger Locy

PHONE: (315) 342-3840