



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 25, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Smoke Detector Covered to
Prevent Actuation During
Welding Activities
LER 83-040/03 L-0
AECM-83/0125

On January 27, 1983, a smoke detector was covered in the Auxiliary Building to prevent actuation while performing welding activities. This required entering the action statement of Technical Specification 3.3.7.9 and is being reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-040/03 L-0.

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8303040358 830225
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

83 FEB 28 AIO: 29

OFFICIAL COPY

1622