



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 1, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Auxiliary Building Equipment  
Hatch Removed to Allow  
Transport of Materials  
LER 83-044/99 X-0  
AECM-83/0137

On January 24, 1983, the equipment hatch on the Auxiliary Building 139 feet elevation, west corridor, was removed to allow transport of materials to the 119 feet elevation. An hourly fire watch was established in accordance with Technical Specification 3.7.7. Attached LER 83-044/99 X-0 is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

*James P. McGaughy, Jr.*  
FOR J. P. McGaughy, JR.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8303040506 830301  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22