



**GPU Nuclear**

P.O. Box 388  
Forked River, New Jersey 08731  
609-693-6000  
Writer's Direct Dial Number:

Mr. Ronald C. Haynes, Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19405

February 25, 1983

Dear Mr. Haynes:

Subject: Oyster Creek Nuclear Generating Station  
Docket 50-219  
I & E Bulletin 82-03

Our letter to you dated December 1, 1982 explained that since the demonstration of our intergranular stress corrosion cracking (IGSCC) detection capability had not yet been accomplished, a full response to item 1 of IE Bulletin 82-03 would be delayed. The demonstration has now been completed with favorable results. The purpose of this letter is to complete the response to I & E Bulletin 82-03, item 1.

Based on information provided by the initial UT team of October 29, 1983 and first hand lessons learned from the December 13-14, 1982 qualification, a change was made to the ultrasonic test procedure. It was decided to add 1dB in sensitivity for calibration to provide a common dB level for calibration and to increase the sensitivity of the technique.

In the event that any comments or questions arise, please call Mr. J. Knubel at (201) 299-2213.

Very truly yours,

Peter B. Fiedler  
Vice President and Director  
Oyster Creek

PBF:jal

cc: NRC Resident Inspector  
Oyster Creek Nuclear Generating Station  
Forked River, NJ 08731

Mr. Darrell G. Eisenhut  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8303040517 830225  
PDR ADOCK 05000219  
Q PDR

FE11