


LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58

0 1 C A S O S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSER CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

REPORT SOURCE: 01 L 050003627 0118838 0217839
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 1453, Unit 3 entered Mode 3 with eight inoperable fire detectors as permitted by the LCO 3.0.4 exception for Tech. Spec. 3.3.3.7. These detectors were for the combustible oil area of Reactor Coolant Pump 3P004 (within Zone 1). On January 23, 1983, at 1310, the detectors were restored to operable condition. The fire deluge system remained manually operable, therefore, public health and safety were not affected.

0 9

SYSTEM CODE A B 11

CAUSE CODE E 12

CAUSE SUBCODE E 13

COMPONENT CODE I N S T R U 14

COMP SUBCODE E 15

VALVE SUBCODE Z 16

17 LER RO REPORT NUMBER

EVENT YEAR 8 3 21 22

SEQUENTIAL REPORT NO. 0 1 9 24 26

OCCURRENCE CODE 0 3 28 29

REPORT TYPE L 30 31

REVISION NO. 0 32

ACTION TAKEN X 18

FUTURE ACTION Z 19 34

EFFECT ON PLANT Z 20 35

SHUTDOWN METHOD Z 21 36

HOURS 0 0 0 0 22 37 40

ATTACHMENT SUBMITTED N 23 41

NPRD-4 FORM SUB N 24 42

PRIME COMP. SUPPLIER A 25 43

COMPONENT MANUFACTURER A 6 0 5 26 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 3 The detectors were inoperable because a spurious alarm prior to Mode 3 entry had not
1 1 been reset. Construction activity in the area of the fire detector is considered the
1 2 cause of the spurious alarm. Compensatory measures required by LCO 3.3.3.7 Action
1 3 Statement 'a' had been initiated. Plant personnel have been instructed in the
1 4 importance of promptly identifying and resetting spurious detector alarms. No
further corrective actions are considered necessary.

8 9
FACILITY STATUS 1 5 8 28 0 0 0 29 N/A 44
7 8 9 10 11 12 13
% POWER
OTHER STATUS
METHOD OF DISCOVERY 45 46 A 31 Operator Observation 80
DISCOVERY DESCRIPTION 32
ACTIVITY CONTENT
RELEASED OF RELEASE 1 6 Z 33 Z 34 N/A 44
7 8 9 10 11 12 13
AMOUNT OF ACTIVITY 35
LOCATION OF RELEASE 36
PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION 39
1 7 0 0 0 37 Z 38 N/A 80
7 8 9 10 11 12 13
PERSONNEL INJURIES
NUMBER DESCRIPTION 41
1 8 0 0 0 40 N/A 80
7 8 9 10 11 12 13
LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION 43
1 9 Z 42 N/A 80
7 8 9 10 11 12 13
PUBLICITY
ISSUED DESCRIPTION 45
2 0 N 44 N/A 80
7 8 9 10 11 12 13
8303040615 830217
PDR ADOCK 05000362
S PDR
NRC USE ONLY
68 69

NAME OF PREPARER H.B. RAY HB Ray / JRM:mny PHONE 714-492-7700

NRC USE ONLY

00000