



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 1, 1983

JAMES P. McGOUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.C  
Fire Door 1A104 Blocked Open  
for Planned Maintenance  
Activities  
LER 83-042/99 X-0  
AECM-83/0132

On January 24, 1983, fire door 1A104 was blocked open to allow passage of welding leads used during planned maintenance activities. An hourly fire watch was established in accordance with Technical Specification 3.7.7. Attached LER 83-042/99 X-0 is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

  
FOR J. P. McGoughy, Jr.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8303040620 830301  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

83 MAR 2 4 9:55

USNRC REGION II  
ATLANTA, GEORGIA

OFFICIAL COPY

LE 22