

SNUPPS

Standardized Nuclear Unit
Power Plant System

5 Choke Cherry Road
Rockville, Maryland 20850
(301) 869-8010

Nicholas A. Petrick
Executive Director

February 2, 1984

SLNRC 84-0020 FILE: 0491.10.2
SUBJ: Final Report: Undetectable Failure
in Solid State Protection System,
10 CFR 50.55(e) Report 82-2

Mr. James G. Keppler
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. John T. Collins
Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Suite 1000, Parkway Central Plaza
Arlington, Texas 76012

Docket Nos. STN 50-482 and STN 50-483

References: 1) Letter, SLNRC 82-036, September 3, 1982: N.A. Petrick (SNUPPS) to NRC, IE Regions III and IV
2) Letter, SLNRC 83-013, March 3, 1983: N.A. Petrick (SNUPPS) to NRC, IE Regions III and IV
3) Letter, SLNRC 83-049, September 2, 1983: N.A. Petrick (SNUPPS) to NRC, IE Regions III and IV
4) Westinghouse (Rahe) letter, NS-EPR-2877, to NRC (DeYdun) dated January 17, 1984.

Gentlemen:


References 1 through 3 provided reports of a deficiency involving the potential for an undetectable failure of a switch in relay testing circuits of the Westinghouse Solid State Protection System (SSPS). A design modification has been finalized to alleviate the potential for a failed switch remaining undetected. Westinghouse informed the NRC of the generic design modification in Reference 4. The modification for Callaway and Wolf Creek involves deletion of the test push-button contact in series with the master relay coil, as noted in Attachment 2 of Reference 4.

With the design modification of Reference 4, no changes to test procedures will be required at Callaway or Wolf Creek. The changes in design details proposed by Westinghouse have been reviewed by SNUPPS and are considered acceptable. As noted in Reference 4, Westinghouse will generate field change notices to govern the equipment modifications at the Callaway and Wolf Creek plants. The modifications will be completed prior to fuel load at both plants.

SLNRC 84- 0020
Page Two

The NRC will be informed should there be significant new developments.
This letter should be considered the final report on this matter. Please
do not hesitate to call should there be any questions regarding this report.

Very truly yours,



Nicholas A. Petrick

RPW/dck/12b21

cc: D. F. Schnell	UE
G. L. Koester	KGE
D. T. McPhee	KCPL
W. S. Schum	NRC/WC
J. H. Neisler	NRC/CAL
B. H. Little	NRC/CAL
R. C. DeYoung	NRC/IE: HQ
J. E. Konklin	NRC/IE: III
Record	