



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

February 10, 1995

TVA-SQN-TS-94-07

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - SUPPLEMENTAL INFORMATION TO
TECHNICAL SPECIFICATION (TS) CHANGE 94-07 (TAC NOS. M91219 AND
M91220)

Reference: TVA letter to NRC dated December 16, 1994, "Sequoyah Nuclear
Plant (SQN) - Technical Specification (TS) Change 94-07,
'Reduction of Maximum Applicable Power Level for Operation
With One or More Main Steam Safety Valves (MSSVs)
Inoperable'"

In accordance with 10 CFR 50.90, we are enclosing an amendment to
Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The
proposed change supplements the above referenced submittal by clarifying the
limits of Mode 3 applicability.

The supplemental changes to the proposed TS change are identified in
Enclosure 1 (affected pages only). The justification for the proposed TS
change is provided in Enclosure 2. Enclosure 3 provides a revised significant
hazard consideration, which contains the original and supplemental
information.

140113

9502140342 950210
PDR ADDCK 05000327
PDR

DO30

U.S. Nuclear Regulatory Commission

Page 2

February 10, 1995

The need for this supplemental response was a result of an oversight when TVA decided to leave the Nuclear Instrumentation System high-neutron flux trip setpoint in the affected TS Section 3.7.1.1.

TVA requests a 45-day implementation period for this TS change following issuance.

Please direct questions concerning this issue to Steve Gilley at 843-7427.

Sincerely,

R. H. Shell

R. H. Shell
Manager
SQN Site Licensing

Sworn to and subscribed before me
this 10th day of February 1995

Gregg M. Bellisople
Notary Public
My Commission Expires Oct 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission
Page 3
February 10, 1995

(Enclosures):

Mr. D. E. LaBarge, Project Manager
Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
3rd Floor
L & C Annex
401 Church Street
Nashville, Tennessee 37243-1532

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711