



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4344

Gary J. Taylor  
Vice President  
Nuclear Operations

February 15, 1995  
Refer to: RC-95-0040

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
PART 21 EVALUATION (SSH 940002)

Reference: South Carolina Electric & Gas Company (SCE&G) Letter RC-94-0308  
Dated December 2, 1994, Interim Part 21 Report (SSH 940002)

In the referenced letter, SCE&G informed the NRC of a defect that was potentially reportable under 10CFR21. The referenced Interim Part 21 report identified the failure of a 27N degraded voltage relay which was manufactured by Asea Brown Boveri (catalog #411T4175-L). Subsequent evaluation by SCE&G, following inspection by the vendor, has determined that this item is not reportable under 10CFR21.

If you require any further information, please contact Mr. Kelley Marsh at (803) 345-4796.

Very truly yours,



Gary J. Taylor

RKM/GJT/nkk

c: O. W. Dixon  
R. R. Mahan  
R. J. White  
S. D. Ebner  
G. F. Wunder  
NRC Resident Inspector  
J. B. Knotts, Jr.  
NSRC  
Central File System  
RTS (SSH 940002)  
File (818.18)

220023



NUCLEAR EXCELLENCE - A SUMMER TRADITION!

9502230282 950215  
PDR ADDCK 05000395  
S PDR

IE19  
1/0