



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 30, 1984

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W. Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416 and 50-417
License No. NPF-13
File 0260/L-835.0/L-401.0
Final Response to IE Bulletin
No. 83-06, Nonconforming
Materials Supplied by Tube-
Line Corporation Facilities
at Long Island City, NY;
Houston, TX; and Carol
Stream, IL
AECM-84/0052

On November 15, 1984, Mississippi Power & Light (MP&L) transmitted an interim response to IE Bulletin No. 83-06, "Nonconforming Materials Supplied by Tube-Line Corporation Facilities at Long Island City, New York; Houston, Texas; and Carol Stream, Illinois", because we had not received information from three sub-vendors. That information has since been received and we are now able to provide a complete response.

As a result of investigations, conducted by MP&L Purchasing, General Electric Co., and Bechtel Power Corporation, it has been concluded that neither unit at the Grand Gulf Nuclear Station (GCNS) has received ASME Code material from the Tube-Line Corporation (T-L). GCNS did purchase eighteen (18) 4-inch 150 pound carbon steel T-L flanges from Consolidated Pipe and Supply of Pascagoula, Mississippi; however, these flanges were purchased and appropriately marked for use in nonsafety-related applications.

To date, our best estimate of staff time used to perform the request evaluation is 332±25 man-hours, of which sixty (60) man-hours were used to prepare written responses.

8402140322 840130
PDR ADOCK 05000416
Q PDR


MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0052

Page 2

Should you require any further information regarding these matters,
please advise.

Yours truly,

A handwritten signature in dark ink, appearing to read "James M. Laughlin". The signature is written in a cursive, flowing style with a large initial "J" and a prominent "M".

JPM:sad


cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

AFFIDAVIT

STATE OF MISSISSIPPI
COUNTY OF HINDS


J. P. McGaughy, Jr., being duly sworn, states that he is Vice President - Nuclear, of Mississippi Power & Light Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this response to IE Bulletin 83-06 on behalf of Company, Middle South Energy, Inc. and South Mississippi Electric Power Association; that he signed the foregoing letter as Vice President - Nuclear, of Mississippi Power & Light Company; and that the statements made and the matters set forth therein are true and correct to the best of his knowledge, information and belief.



J. P. McGaughy, Jr.

SUBSCRIBED AND SWORN TO before me, a Notary Public, in and for the County and State above named, this 30th day of January, 1984.

(SEAL)



Notary Public

My commission expires:

My Commission Expires Sep. 21, 1987.