

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

D. L. Rehn
Vice President
(803)831-3205 Office
(803)831-3426 Fax



DUKE POWER

February 6, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 1
Docket No. 50-413
Technical Specification Amendment Supplement
Renewal Of Steam Generator Tube Interim Plugging Criteria for Unit 1 Cycle 9

Reference: Letter from D. L. Rehn to NRC, same subject, dated November 29, 1994

As a result of recent telephone discussions between Duke Power Company and the NRC, Catawba is committing to the following items relative to the referenced Technical Specification Amendment Request:

1. Catawba will perform a tube pull in the event of a forced outage on Unit 1 during Cycle 9, if the forced outage is due to a S/G Tube leak as a result of ODSCC at the Tube Support Plate. Catawba will pull the leaking intersection and will pull additional intersections as engineering judgment dictates.
2. The IPC Repair criteria is not applicable at the Flow Distribution Baffle Plate intersections.
3. All known tube leaks will be repaired.
4. Analysts will be briefed on the possibility that Primary Water Stress Corrosion Cracking (PWSCC) can occur at the Tube Support Plate intersections. If PWSCC is identified at the Tube Support Plates, this will be reported to the NRC prior to restart of the Unit.

Should you have any questions, please call Devereux Tower at 803-831-3419.

9502240226 950206
PDR ADUCK 05000413
P PDR


Printed on recycled paper

Accol
1/10

• Nuclear Regulatory Commission
February 6, 1995
Page 2

Pursuant to 10 CFR 50.91 (b)(1), the appropriate South Carolina official is being provided a copy of this amendment request supplement.

Very truly yours,

A handwritten signature in dark ink, appearing to read "DL Rehn", with a long horizontal flourish extending to the right.

D. L. Rehn

Attachments

DT/

Nuclear Regulatory Commission

November 14, 1994

Page 3

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Mr. Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health &
Environmental Control
2600 Bull Street
Columbia, SC 29201

Mr. R. J. Freudenberger
NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert E. Martin, Project Manager
ONRR

Mr. Ashok C. Thadni, Associate Director
Inspection & Technical Assessment
ONRR

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

M & M Nuclear Consultants
1166 Avenue of the Americas
New York, NY 10036-2774

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339