

LOUISIANA POWER & LIGHT COMPANY
WATERFORD SES UNIT NC, 3

RESPONSE TO NRC DRAFT - TECHNICAL EVALUATION REPORT (TER) FOR
WATERFORD 3 SES ON CONTROL OF HEAVY LOADS

SUPPLEMENT NO. 1

November 1983

8402150313 840209
PDR ADDCK 05000392
E PDR

CONTENTS

	<u>Page</u>
1.0 <u>INTRODUCTION</u>	1
2.0 <u>REACTOR VESSEL (CLOSURE) HEAD LIFTING RIG</u>	1
3.0 <u>TABLE NO. 1</u>	6
SUMMARY OF STRESS LEVELS AND SAFETY FACTORS IN HEAD LIFT RIG COMPONENTS	

ATTACHMENT:

Figure III - Lifting Rig to Closure Head

1.0 INTRODUCTION

Pursuant to our commitment in our "Response to NRC Draft - Technical Evaluation Report (TER) for Waterford 3 SES on Control of Heavy Loads dated January 1983" to submit a compliance evaluation for the Reactor Vessel (Closure) Head Lift Rig when review is completed by the rig vendor, we are now herein submitting the results of our evaluation in this Supplement No. 1.

We have evaluated the lift rig design and fabrication for compliance with Guideline 4 - Special Lifting Devices, [NUREG-0612, Article 5.1.1(4)] and the associated requirements of ANSI N14.6-1978.

2.0 REACTOR VESSEL (CLOSURE) HEAD LIFTING RIG

This rig is listed as Item No. 1 of Section 6.0 in the "Response to NRC Draft - Technical Evaluation Report (TER) for Waterford 3 SES on Control of Heavy Loads dated January 1983."

A stress summary for the rig using static plus dynamic loads are shown on Table 1 (Page 6).

The following tabulation lists the Section Referenced and the degree of compliance for the above-listed rig.

<u>ANSI N14.6-1978</u> <u>Section Referenced</u>		<u>Reactor Vessel (Closure)</u> <u>Head Lift Rig</u>
<u>Section 3.1</u>		
3.1.1	Limitations on the use of lifting devices	Used only for the RV closure head and the cavity seal plate
3.1.2	Identification of critical components and definition of critical characteristics	All lifting components are considered critical. See Table 1 (Page 6) for listing.
3.1.3	Signed stress analyses, demonstrating appropriate margins of safety	Safety margins demonstrated on Table 1 (Page 6)
3.1.4	Indication of permissible repair procedures	Repairs shall be made to comply with original Lift Rig Specifications. Fabricator (repairer) has responsibility for detailed repair procedures.
<u>Section 3.2</u>		
3.2.1	Use of stress design factors of 3 for minimum yield strength and 5 for ultimate strength	See Table 1 (Page 6) for stress evaluation.

ANSI N14.6-1978
Section Referenced

Reactor Vessel (Closure)
Head Lift Rig

- 3.2.4 Similar stress design factors for load bearing pins, links, and adapters.
- 3.2.5 Slings used comply with ANSI B30.9.
- 3.2.6 Subject materials to deadweight test or charpy impact test

See Table 1 (Page 6) for stress evaluation.

Not applicable since no rope or chain is used for lifting.

Vital numbers identified with their piece numbers, were impact tested using the charpy V-notch method. The required values listed in Section III of ASME Code 1971 Edition through Summer 1973 Addenda, were met at +10°F.

Section 3.3

- 3.3.1 Consideration of problems related to possible galling
- 3.3.4 Design shall assure even distribution of the load
- 3.3.5 Retainers fitted for load carrying components which may become inadvertently disengaged
- 3.3.6 Verification that remote actuating mechanisms securely engaged or disengaged

No lifting element is subject to lamellar tearing.

See Table 1 (Page 6) for compliance.

All vital members with connecting pins have cotter pins for positive locking against unplanned disengagement.

Not applicable since no remote actuating mechanisms are used.

Section 4.1

- 4.1.3 Verify selection and use of material
- 4.1.4 Compliance with fabrication practice

Materials verified from mill test reports or certifications and reviewed for compliance to the design specification.

Fabrication practices complied in accordance with approved procedures and methods as verified by surveillance and receipt inspection of components.

ANSI N14.6-1978
Section Referenced

Reactor Vessel (Closure)
Head Lift Rig

4.1.5 Qualification of welders,
procedures, and operators

Weld procedures, materials
and operators were qualified
under Section IX of the ASME
Boiler and Pressure Vessel
Code.

4.1.6 Provisions for a quality
assurance program

All requirements of the
design specification were
performed under a quality
assurance program in effect
at the time of fabrication.

4.1.7 Provisions for identification
certification of materials

All material identified by
piece numbers and/or code
numbers in accordance with
drawing requirements.
Material certifications
conforms to design
specification.

4.1.9 Verification that materials
or services are produced under
appropriate controls and
qualifications

Certificate of Equipment
letter issued by vendor
verifying compliance with
design specification
controls.

Section 5.1

5.1.3 Implementation of a periodic
testing schedule and a system
to indicate the date of
expiration.

NDE in accordance with ASME
B&PV Code for Class 2
Component Supports.
However, visual inspection of
rig prior to use is
recommended.

5.1.4 Provisions for establishing
operating procedures

Procedures for the use of
Lift Rig are detailed in the
removal of the RV head
Instruction Manual.

5.1.5.1 Identification of subassemblies
may be exchanged

No part is to be exchanged
with a part from a similar
rig without a detailed study
of the geometry and the
material pedigree.

5.1.5.2 Suitable Markings

Complies

ANSI N14.6-1978
Section Referenced

Reactor Vessel (Closure)
Head Lift Rig

5.1.6 Maintaining a full record of history

This requirement is being met as follows:

- a) This device is used to lift the RV head only.
- b) The lift rig is qualified for predetermined load.
- c) The lift rig is visually inspected prior to every lift.
- d) The lift rig is used during the refueling outage only.

5.1.7 Conditions for removal from service

Subject to results of NDE testing and inspection.

Section 5.2

5.2.1 Load test to 150 percent and appropriate inspections prior to initial use

The rig was load tested to 125 percent of its design load.

5.2.2 Qualification of replacement parts

Replacement parts are to be fabricated to original criteria and will be load tested by Fabricator or LP&L.

Section 5.3

5.3.1 Satisfying annual load test or inspection requirements

Annual inspection and NDE in accordance with ASME B&PV Code for Class 2 Component Supports.

5.3.2 Testing following major maintenance

There are no requirements for load testing after major maintenance. However, it is recommended that any repairs be analytically evaluated and NDE tested on a case-by-case basis.

5.3.4 Testing after application of substantial stresses

It is recommended that no load test should be done unless the results of the analytical evaluation and NDE testing show a need for it.

ANSI N14.6-1978
Section Referenced

Reactor Vessel (Closure)
Head Lift Rig

5.3.6	Inspections by operating personnel	Not applicable
5.3.7	Nonoperating or maintenance personnel	Not applicable

This special lifting device was designed and fabricated before the issuance of ANSI N14.6-1978 and thus does not meet all requirements in the standard. However, the fabrication methods met the intent of the standard. The device was load tested prior to first use and will be inspected before every use.

TABLE NO. 1



SUMMARY OF STRESS LEVELS AND SAFETY FACTORS IN HEAD LIFT RIG COMPONENTS

REF: COMBUSTION ENGINEERING REPORT CENC-1259, CONTRACT NO. 74170, 6/76 AND
CE LETTER C-CE-8445 DATED APRIL 15, 1983

Element	Stress Condition	Normal Load Stress	Minimum Yield Strength	Minimum Ultimate Strength	Material	Ratio: Yield/Normal	Ratio: Ultimate/Normal
Tripod Lifting Eye	Tension	7.8	36.0	70.0	SA-105-2	4.6	9.0
	Shear	7.8	20.4 ¹	46.7 ²	SA-105-2	2.6*	6.0
Tripod Lifting Eye Shank	Tension	12.7	36.0	70.0	SA-105-2	2.8*	5.5
	Shear	7.0	20.4 ¹	46.7 ²	SA-105-2	2.9*	6.7
Lifting Frame Lug	Tension	6.0	38.0	70.0	SA-516-70	6.3	11.7
	Shear	8.4	21.5 ¹	46.7 ²	SA-516-70	2.6*	5.6
	Bearing	12.4	38.0	70.0	SA-516-70	3.1	5.6
Pin	Shear	7.9	42.5 ¹	66.2 ²	SA-193-B7	5.4	8.4
	Bearing	12.4	75.0	100.0	SA-193-B7	6.0	8.1
Rod	Tension	10.1	131.4 ³	158.2 ³	4340	13.0	15.7
	Shear (Thd)	4.2	74.5 ¹	105.5 ²	4340	17.7	25.1
Clevis	Tension	7.6	36.0	70.0	SA-105-2	4.7	9.2
	Shear	7.6	20.4 ¹	46.7 ²	SA-105-2	2.7*	6.1
	Bearing	9.8	36.0	70.0	SA-105-2	3.7	7.1
Support Strut and Weld	Compression	6.4	35.0	60.0	SA-106-B	5.5	9.4
	Shear	6.3	19.8 ¹	40.2 ²	SA-106-B	3.1	6.3
Extension Legs and Weld	Tension	6.5	36.0	58.0	SA-36	5.5	8.9
	Shear	4.5	20.4 ¹	38.7 ²	SA-36	4.5	8.6
Skirt Lug and Weld	Bearing	8.8	38.0	70.0	SA-516-70	4.3	7.9
	Tension	6.0	38.0	70.0	SA-516-70	6.3	11.7
	Shear (Lug)	6.0	21.5 ¹	46.7 ²	SA-516-70	3.6	7.8
	Shear (Weld)	3.3	21.5 ¹	46.7 ²	SA-516-70	6.5	14.1
Skirt	Tension	2.5	38.0	70.0	SA-516-70	15.2	28.0
Stud	Tension	3.4	75.0	100.0	SA-193-B7	22.1	29.4
	Shear (Ext Thds)	4.3	42.5	66.7	SA-193-B7	9.9	15.5
	Shear (Int Thds)	3.7	42.5	66.7	SA-193-B7	11.5	18.0

1 .58 minimum tensile yield 2 .67 minimum ultimate tensile 3 taken from mill certificate of tests

* The safety margins are lower than required by ANSI H14.6-1978. However, the safety margins are not significantly lower than the required.



LOUISIANA
POWER & LIGHT CO.
Waterford Steam
Electric Station

Lifting Rig to Closure Head

Figure
III