



Carolina Power & Light Company

84 FEB 13 9:32

P. O. Box 165, New Hill, North Carolina 27562
February 7, 1984

FILE: SH N-2/18
Item 140

MQAH 84-55

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400

HANGER SKETCH INCORRECTLY IDENTIFIED FIELD WELDS AS SHOP WELDS

Dear Mr. O'Reilly:


This is to confirm the February 6, 1984 telephone conversation between Mr. K. V. Hate' (CP&L) and Mr. A. Hardin (NRC). Mr. Hardin was informed that the August 15, 1983 potentially reportable item, pertaining to a hanger sketch that incorrectly identified field welds as shop welds, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e).

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. R. C. DeYoung
Mr. G. Maxwell
Mr. R. L. Prevatte


N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

8402150388 840207
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

Id 27
1/0