



LOUISIANA
POWER & LIGHT

142 DELARONDE STREET
NEW ORLEANS, LOUISIANA

P.O. BOX 8008

70174-8008

(504) 366-2345

February 10, 1984

W3P84-0319

3-A20.18

Director of Nuclear Reactor Regulation
Attention: Mr. G. W. Knighton
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: Waterford 3 SES
Docket No. 50-382
Seismic Qualification of Equipment

REFERENCE: LP&L Letter W3P83-1880 dated 8/5/83

Dear Sir:

Please find attached the latest revision to the Seismic Qualification Completion Schedule which supercedes that transmitted to you by the referenced letter. Only resolution of minor questions prevent closing the outstanding files and we fully expect these to be completed prior to fuel load.

Yours very truly,

K. W. Cook
Nuclear Support & Licensing Manager

KWC/RMF/cb

cc: E. L. Blake, W. M. Stevenson, J. Wilson, G. L. Constable, J. Jackson

8402160106 840210
PDR ADOCK 05000382
A PDR

Asy8
1/1

SEISMIC QUALIFICATION COMPLETION SCHEDULE

Rev 1 10/15/83 Rev 7 7/6/83
 Rev 2 1/21/83 Rev 8 8/15/83
 Rev 3 3/2/83 Rev 9 9/15/83
 Rev 4 4/1/83 Rev 10 11/15/83
 Rev 5 5/4/83 Rev 11 2/1/84
 Rev 6 6/1/83

P.O./SPEC	VENDOR/EQUIPMENT (TAG NOS.)	SORT FILE NO./ DR NO	QUALIFICATION SCHEDULE/ REMARKS
<u>NSSS- Plant Engineering (PE)</u>			
LP&L PO L-11911-D	Computer Products Inc APC Multiplexors	No File Established	Test report under LP&L review; review expected to be complete by mid-February.
<u>BOP-Electrical</u>			
403659	BIW: Cable Seal Assemblies	SQ-E-86	PO requisition to BIW on 7/26/83. Reports are expected by 9/20/83. Reports reviewed by Ebasco and additional information has been requested. BIW response by 11/18/83. Report received - SAG review by 1/17/84. Additional information still required; requested via LW3-179-84, dated 2/3/84. Response expected early February.
403517	Cooper Energy Services Diesel Generator Sets	File not established yet All items closed per letter: LW3-952-83, dated 6/30/83 Except: 1) Check Valve (GD 9-36876#2) 2) Fisher Press. Regulator (2-04V-09B-001) 3) Versa 3-Way Valve (2-05V-101-002) 4) Heyman Press Gauge (2-01J-610-012)	CES response by 8/22/83. Ebasco resolution by 8/31/83. CES reports received 9/7/83. Ebasco review complete by 9/23/83. Additional information required by Ebasco has been requested via LW3-1445-83, dated 10/26/83. Response expected week of 2/6/84.

SEISMIC QUALIFICATION
COMPLETION SCHEDULE

P.O./SPEC	VENDOR/EQUIPMENT (TAG NOS.)	SORT FILE NO./ DR NO	QUALIFICATION SCHEDULE/ REMARKS
<u>BOP-Mechanical</u> NY-403805	Joseph Oat Corp Breathing Air Storage Tanks	No File Established Yet	Part I report has been reviewed with comments: LW3-1045-83, dated 7/26/83. Part II reviewed with comments, letter to be issued by 9/15/83. Response letter from J Oats received 10/20/83. Report has now been reviewed without comments Acceptance letter by 11/30/83. Acceptance letter issued LW3-1570-83, dated 11/21/83. Item will be deleted next update.
<u>BOP-App Phy</u> 403621	General Atomic Isokenetic Nozzle	No Files Established Yet	Report returned to vendor with comments. Response by vendor expected 9/30/83. Information received from GA. Ebasco review in progress - complete by 2/8/84.

SEISMIC QUALIFICATION
COMPLETION SCHEDULE

P.O./SPEC	VENDOR/EQUIPMENT (TAG NOS.)	SORT FILE NO./ DR NO	QUALIFICATION SCHEDULE/ REMARKS
BOP - I&C			
403638	Electro Switch Isolation Relays	No File Established	Report reviewed - doesn't address resonant search for 1-1.6 Hz - awaiting additional information from Acton Labs.
403588	Bourns Potentiometer	No File Established	SAG accepted for other panels - being evaluated for CP-33
403519	PAC System - PAC Cards	No File Established	Report in house for review - complete by 2/8/84.