



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4344

Gary J. Taylor
Vice President
Nuclear Operations

February 21, 1995
Refer to: RC-95-0048

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:


Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
REVISION TO CORE OPERATING LIMITS REPORT (RFL 100)

In accordance with Section 6.9.1.11 of the Virgil C. Summer Nuclear Station Technical Specifications, South Carolina Electric & Gas Company (SCE&G) hereby submits Revision 1 to the Cycle 9 Core Operating Limits Report.

The COLR FΔh limit is being increased from 1.56 to 1.62 by allocations from DNB and PCT margins under the provisions of 10CFR50.59. The evaluations utilized approved methodologies, with the large break LOCA crediting the revised Burst Strain Limit Model as previously reported in the V. C. Summer Nuclear Station 1993 Annual 10CFR50.46 Report (Reference letter RC-94-0152, dated June 6, 1994).

Should you have any questions concerning this report, please call Mr. Philip Rose at (803) 345-4052 at your convenience.

Very truly yours,


Gary J. Taylor

PAR/GJT/nkk
Attachment

c: O. W. Dixon
R. R. Mahan (w/o Attachment)
R. J. White
S. D. Ebnetter
S. Dembek
NRC Resident Inspector
J. B. Knotts Jr.
NSRC
CFS
RTS (RFL 100)
File (818.23-1)

9503020057 950221
PDR ADDOCK 05000395
P PDR



NUCLEAR EXCELLENCE - A SUMMER TRADITION!

Handwritten: 1001 1/1