

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2

DOCKET NUMBER (2)

0 5 0 0 0 3 6 1 1 OF 0 1

PAGE (3)

TITLE (4)

FIRE PROTECTION PROGRAM DEFICIENCIES

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0	1	1	8	4	0	0	1		UNIT 3		0 5 0 0 0 3 6 2
											0 5 0 0 0

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)									
POWER LEVEL (10)	1	20.402(b)		20.406(e)		50.73(a)(2)(iv)		73.71(b)		
1	0	20.406(a)(1)(i)	X	50.36(e)(1)		50.73(a)(2)(v)		73.71(e)		
		20.406(a)(1)(ii)		50.36(e)(2)	X	50.73(a)(2)(vii)	X	OTHER (Specify in Abstract below and in Text, NRC Form 356A)		
		20.406(a)(1)(iii)	X	50.73(a)(2)(i)		50.73(a)(2)(viii)(A)				
		20.406(a)(1)(iv)	X	50.73(a)(2)(ii)		50.73(a)(2)(viii)(B)				
		20.406(a)(1)(v)		50.73(a)(2)(iii)		50.73(a)(2)(ix)				

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
J. G. HAYNES, STATION MANAGER	7 1 4 4 9 2 - 7 7 0 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
X			0	2	8 4

ABSTRACT (Limit to 1400 spaces, i.e., approximately five to single-space typewritten lines) (16)

As reported on January 11, 1984, pursuant to 10 CFR 50.72(b)(1)(ii)(B), the preparation of the updated Fire Hazards Analysis (FHA) and the review of routine fire protection surveillance results, have resulted in the issuance of Nonconformance Reports (NCR's) identifying deficiencies in implementing and maintaining in effect all provisions of the Fire Protection Program. These deficiencies involve: Fire protection spray/sprinkler and water supply systems; cable separation and fire wraps; fire barriers; and, fire/smoke detectors and associated systems.

Our review into this matter is continuing and in order to provide a complete response, additional time is required. A complete report will be submitted by February 28, 1984.

8402210245 840213
PDR ADOCK 05000361
S PDR

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

February 13, 1984

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 84-001
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated January 26, 1984, "14-Day Follow-up Report"

Pursuant to 10 CFR 50.36, 50.73, and License Condition 2.G to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this submittal provides the required 30-day written Licensee Event Report (LER) for Fire Protection Program deficiencies. As indicated in the referenced letter, these deficiencies were discovered during routine surveillances and during the preparation of the updated Fire Hazards Analysis. Since this occurrence involved shared systems between Units 2 and 3, a single LER for Unit 2 is enclosed in accordance with NUREG-1022.

Our review into this matter is continuing. In order to provide a complete response, additional time is required. As indicated in Blocks 14 and 15 of the enclosed LER, the supplemental report will be submitted by February 28, 1984. The health and safety of plant personnel or the public were not affected by this occurrence.

If you require any additional information, please so advise.

Sincerely,

Enclosure: LER No. 84-001

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, NRC Region V)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

Institute of Nuclear Power Operations (INPO)

IE22
1/1