



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

February 4, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Units 1 and 2
Primary Containment Isolation Following
Reset of Isolation Signals
NRC Docket Nos. 50-373 and 50-374

References (a): C. W. Schroeder letter to H. R. Denton
dated November 28, 1983.

(b): C. W. Schroeder letter to H. R. Denton
dated December 7, 1983.

Dear Mr. Denton:

Reference (a) provided an extensive summary and review of the actions taken regarding primary containment isolation following reset of the isolation signal. Reference (b) provided an interim commitment to also place caution cards on the Unit 2 E12-F099A and B valves. In additional discussions with Dr. A. Bournia of your staff, it was indicated that NRR had made a determination that the safety significance involved with the Unit 1 and Unit 2 valves in question is minimal. Because, however, the modifications required to change the valves were not complex, NRR would request that the valves be modified.

The purpose of this letter is to provide the following commitments:

For Unit 1, prior to startup after the first refueling outage, the following valves will be modified (or eliminated) so that, following a primary containment isolation, resetting of the isolation signal will not potentially result in automatic change of position of the valves.

| | |
|------------|-----------------------------|
| 1E21-F333 | (Potential for elimination) |
| 1E22-F354 | (Potential for elimination) |
| 1E51-F354 | (Potential for elimination) |
| 1E51-F355 | (Potential for elimination) |
| 1E12-F099A | |
| 1E12-F099B | |

8402210265 840204
PDR ADOCK C5000373
P PDR

*Accol
1/10*

H. R. Denton

- 2 -

February 4, 1984

For Unit 2, prior to exceeding 5% power, the following valves will be modified so that, following a primary containment isolation, resetting of the isolation signal will not potentially result in automatic change of position of the valves.

2E12-F099A
2E12-F099B

To the best of my knowledge and belief the statements contained herein and in the attachment are true and correct. In some respects these statements are not based on my personal knowledge but upon information furnished by other Commonwealth Edison and contractor employees. Such information has been reviewed in accordance with Company practice and I believe it to be reliable.

One signed original and forty (40) copies of this letter are provided for your use.

If there are any further questions regarding this matter, please contact this office.

Very truly yours,

CW Schroeder 2/4/84

C. W. Schroeder
Nuclear Licensing Administrator

lm

cc: J. G. Keppler
NRC Resident Inspector

8076N