





# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

84 FEB 17 1984

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update Report - Fire Rated  
Door OC104 Blocked Open to  
Route Hose  
LER 83-031/99 X-3  
AECM-84/0073

This is an update to a previous update report submitted on September 8, 1983. The event for which the report was submitted occurred on January 13, 1983, when fire rated door OC104 was blocked open to route a temporary discharge hose from the Hot Machine Shop sump to the Turbine Building floor drain system. An hourly fire watch was established in accordance with Technical Specification 3.7.7. The event was reported pursuant to Technical Specification 6.9.2.

The purpose of this report is to revise the estimated date of restoration to April 15, 1984. Attached is LER 83-031/99 X-3 which is a final report.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

EBS/SHH:sad  
Attachment

cc: (See Next Page)

OFFICIAL COPY

2622

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0073

Page 2

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555