

**TEXAS UTILITIES GENERATING COMPANY**

SKYWAY TOWER \* 400 NORTH OLIVE STREET, L.B. 81 \* DALLAS, TEXAS 75201

**R. J. GARY**  
EXECUTIVE VICE PRESIDENT

February 13, 1984  
TXX-4107

Mr. E. H. Johnson, Chief  
Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos.: 50-445  
50-446


COMANCHE PEAK STEAM ELECTRIC STATION  
PIPE SUPPORT DESIGN ERROR  
QA FILE: CP-84-06, SDAR-130  
FILE: 10110

Dear Mr. Johnson:

On January 18, 1984, we verbally informed your Mr. R. G. Taylor of a discrepancy regarding the section modulus used in the design of pipe supports using tube steel.

We have completed our investigation and concluded that the matter is not reportable under 10CFR50.55(e). Records supporting this determination are available for your inspector's review at the CPSES site.

Very truly yours,



RJG:ln

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8402220171 840213  
PDR ADDCK 05000445  
S PDR

IE-27

1/0