

CONTROL BLOCK

PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

01 N C M G S 2 00 - 000000 - 000 411111 5

CONT

01 REPORT SOURCE L 505000370 091583 092883 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 1, review of a condition identified on Catawba Nuclear Station deter-
03 mined that an adequate fire barrier is not provided between electrical penetration
04 rooms located in the Auxiliary Building on Elevations 733' and 750'. This consti-
05 tutes a degradation of fire barrier penetrations (T.S.3.7.11) which is reportable
06 pursuant to T.S.6.9.1.11(b) and similar to R0-369/83-72. Fire detectors in the area
07 were verified operable and hourly fire watch patrols have been established. Health
08 and safety of the public were unaffected.

09 SYSTEM CODE A B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE P E N E T R 14 COMP SUBCODE X 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 83 18 EVENT YEAR 83 19 SEQUENTIAL REPORT NO. 044 20 OCCURRENCE CODE 03 21 REPORT TYPE L 22 REVISION NO. 0

23 ACTION TAKEN X 24 FUTURE ACTION F 25 EFFECT ON PLANT Z 26 SHUTDOWN METHOD Z 27 HOURS 0000 28 ATTACHMENT SUBMITTED Y 29 NPD-4 FORM SUB. N 30 PRIME COMP. SUPPLIER L 31 COMPONENT MANUFACTURER X999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The three inch seismic gap in areas where the Auxiliary Building abutts the Reactor
11 and Diesel Generator Building has compressed cork installed as filler material.
12 This situation was inadvertently overlooked during identification of fire barrier
13 penetrations. The cork will be removed and replaced with an approved fire rated
14 material, and the penetration added to surveillance procedures.

15 FACILITY STATUS B 28 % POWER 075 29 OTHER STATUS NA 30 METHOD OF DISCOVERY C 31 DISCOVERY DESCRIPTION Design Engineering Review 32

33 ACTIVITY CONTENT RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

37 PERSONNEL EXPOSURES NUMBER 000 38 TYPE Z 39 DESCRIPTION NA

40 PERSONNEL INJURIES NUMBER 000 41 DESCRIPTION NA

42 LOSS OF OR DAMAGE TO FACILITY TYPE Z 43 DESCRIPTION NA

44 PUBLICITY ISSUED N 45 DESCRIPTION NA

46 NRC USE ONLY

NAME OF PREPARER Phillip B. Nardoci

PHONE (704) 373-7432