



Carolina Power & Light Company

93 OCT 3 9:43

P. O. Box 101, New Hill, N. C. 27562  
September 29, 1983

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest (Suite 2900)  
Atlanta, Georgia 30303

NRC-124

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT  
1986-90 - 900,000 KW - UNITS 1 & 2  
BUS DUCT AND TRANSFORMER WELD DEFICIENCIES, ITEM 143

Dear Mr. O'Reilly:

On September 2, 1983, Mr. K. V. Hate' notified the NRC (Mr. P. Bemis) of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The NRC was informed that vendor weld deficiencies were noted by CP&L in sections of Bus Duct numbers CC-1 and CC-2 and Transformer numbers 1D1, 1D2, 1E1, and 1E2 received from Gould-Brown-Boveria, Chalfont, Pennsylvania.

CP&L is currently investigating this item and awaiting a response from the vendor. It is projected that the vendor will require until January 1984 to respond with their evaluation. For this reason, we will require until January 13, 1984 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,

R. M. Parsons  
Project General Manager  
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)  
Mr. R. C. DeYoung (NRC)

8310060336 830929  
PDR ADDCK 05000400  
S PDR

OFFICIAL COPY

IE 27  
1/0