



Consumers
Power
Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

October 3, 1983

James G Keppler, Administrator
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - SUPPLEMENTAL INFORMATION TO LICENSEE EVENT REPORT 82-34
(INOPERABLE FIRE ALARMS)

Licensee Event Report 82-034 (Inoperable Fire Alarms) committed to investigating the possibility of installing reflash capability for Panel C-13. A Specification Change has received approval which, upon implementation, will modify Panel C-47 and provide fire deluge system reflash capability on Panel C-13.

Brian D Johnson
Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement
NRC Resident Inspector - Palisades

8310120064 831003
PDR ADOCK 05000255
S PDR

OC0983-0022AA-NL02

IE22
OCT 5 1983 1/0