

ATTACHMENT 2

LIMERICK GENERATING STATION

UNITS 1 AND 2

Docket Nos. 50-352
50-353

License Nos. NPF-39
NPF-85

TECHNICAL SPECIFICATIONS CHANGE REQUEST

No. 94-02-0

LIST OF AFFECTED PAGES

UNIT 1

UNIT 2

3/4 3-87

3/4 3-87

TABLE 4.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Vessel Pressure	M	R
2. Reactor Vessel Water Level	M	R
3. Suppression Chamber Water Level	M	R
4. Suppression Chamber Water Temperature	M	R
5. Suppression Chamber Air Temperature	M	R
6. Primary Containment Pressure	M	R
7. Drywell Air Temperature	M	R
8. Drywell Oxygen Concentration Analyzer	M	Q#
9. Drywell Hydrogen Concentration Analyzer	M	Q*
10. Safety/Relief Valve Position Indicators	M	R
11. Primary Containment Post LOCA Radiation Monitors	M	R**
12. North Stack Wide Range Accident Monitor***	M	R
13. Neutron Flux	M	R

*Using calibration gas containing:

Seven volume percent hydrogen, balance nitrogen.

**CHANNEL CALIBRATION shall consist of an electronic calibration of the channel, not including the detector, for range decades above 10 R/h and a one point calibration check of the detector below 10 R/h with an installed or portable gamma source.

***High range noble gas monitors

#Using calibration gas containing:

Seven volume percent oxygen, balance nitrogen.

TABLE 4.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Vessel Pressure	M	R
2. Reactor Vessel Water Level	M	R
3. Suppression Chamber Water Level	M	R
4. Suppression Chamber Water Temperature	M	R
5. Suppression Chamber Air Temperature	M	R
6. Primary Containment Pressure	M	R
7. Drywell Air Temperature	M	R
8. Drywell Oxygen Concentration Analyzer	M	Q#
9. Drywell Hydrogen Concentration Analyzer	M	Q*
10. Safety/Relief Valve Position Indicators	M	R
11. Primary Containment Post LOCA Radiation Monitors	M	R**
12. North Stack Wide Range Accident Monitor***	M	R
13. Neutron Flux	M	R

*Using calibration gas containing:

Seven volume percent hydrogen, balance nitrogen.

**CHANNEL CALIBRATION shall consist of an electronic calibration of the channel, not including the detector, for range decades above 10 R/h and a one point calibration check of the detector below 10 R/h with an installed or portable gamma source.

***High range noble gas monitors

#Using calibration gas containing:

Seven volume percent oxygen, balance nitrogen.