

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 4 8 7 0 9 1 2 8 3 8 1 0 0 4 8 3 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 2109 on 9/12/83, the instrumentation channel associated with flow transmitter

03 FT-415 (RCS Loop 1) was declared inoperable due to its erratic indication. Tech.

04 Spec. 3.3.1, in part, requires this channel to be operable. Tech. Spec. 3.3.1

05 action statement requirements were met. Health/safety of the public was not

06 affected.

07

08

09 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE G 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE Y 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 8 3 21 EVENT YEAR 8 3 22 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26

ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was caused by failure of an NLP card. The card was replaced and

11 following satisfactory performance of FNP-1-STP-201.8 (Reactor Coolant System

12 FT-415 Loop Calibration and Functional Test), the FT-415 instrumentation channel

13 was declared operable at 1445 on 9/16/83.

14

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operational Event 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 TYPE NA 41 DESCRIPTION NA 42

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156

NRC USE ONLY