

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)0 1 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CONT

0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 9 | 1 | 3 | 8 | 3 | 8 | 1 | 0 | 0 | 4 | 8 | 3 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0015 on 9/13/83, during performance of FNP-1-STP-201.1 (Pressurizer Level

0 3 | QIB31LT0459 Calibration and Functional Test), the instrumentation channel as-

0 4 | sociated with level transmitter LT-459 (Pressurizer Level - Narrow Range) was

0 5 | declared inoperable when it was determined to be out of tolerance. Tech. Spec.

0 6 | 3.3.1, in part, requires this channel to be operable. Tech. Spec. 3.3.1 action

0 7 | statement requirements were met. Health/safety of the public was not affected.

0 8 |

0 9 | SYSTEM CODE | I | A | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | G | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | Y | 15 | VALVE SUBCODE | Z | 16 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

17 | LER/RO REPORT NUMBER | 8 | 3 | EVENT YEAR | 8 | 3 | SEQUENTIAL REPORT NO. | 0 | 6 | 1 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | 1 | REVISION NO. | 0 |

21 22 23 24 25 26 27 28 29 30 31 32 33 34

ACTION TAKEN | A | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | N | 23 | NPRD-4 FORM SUB. | Y | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | W | 1 | 2 | 0 |

33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by failure of an NLP card. The card was replaced and

1 1 | following satisfactory completion of FNP-1-STP-201.1, the LT-459 instrumentation

1 2 | channel was declared operable at 0430 on 9/13/83.

1 3 |

1 4 |

1 5 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45 |

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34

8310120363 831004
PDR ADCK 05000348
S PDR

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156

NRC USE ONLY