

U.S. NUCLEAR REGULATORY COMMISSION  
LICENSEE EVENT REPORTAPPROVED BY OMB  
3150-0011

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 2 00 - 000000 - 00 411111 5  
7 8 9 14 15 25 26 30 37 CAT 38

CONT

01 REPORT SOURCE L 05000364 7090783 6100483 9  
7 8 60 61 68 69 74 75 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0800 on 9/7/83, during performance of FNP-2-STP-605.4 (Auxiliary Building  
03 Battery Quarterly Verification), battery bank 2A was declared inoperable due to  
04 a decrease in voltage of greater than 0.1 volts on cell #56 since the last  
05 quarterly inspection. Tech. Spec. 3.8.2.3, in part, requires this battery bank  
06 to be operable. Tech. Spec. 3.8.2.3 action statement requirements were met.  
07 Health/safety of the public was not affected. A similar occurrence was reported  
08 in LER 83-026/03L-0 (Unit 2).

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
E C 11 X 12 Z 13 B A T T E R Y 14 Z 15 Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
17 LER/NO REPORT NUMBER 83 037 03 L 0  
21 22 23 24 25 26 27 28 29 30 31 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
X 18 Z 19 Z 20 Z 21 00000 N 23 N 24 A 25 G 1 8 5  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This event was caused by a decrease in voltage on an individual cell. The top  
11 of the cell was cleaned and the cell was charged. Following satisfactory  
12 completion of FNP-2-STP-605.4, battery bank 2A was declared operable at 0930  
13 on 9/7/83.

14  
15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
X 28 09 4 29 Cooldown B 31 Surveillance Test  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
Z 33 Z 34 NA NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
000 37 Z 38 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
18 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
000 40 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
Z 42 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
20 PUBLICITY ISSUED DESCRIPTION 45  
N 44 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

8310120371 831004  
PDR ADOCK 05000348  
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156