



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

DMA

October 4, 1983

Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137


Operating License DPR-74
Docket Nos. 50-316

Dear Mr. Keppler:

This is to confirm a notification made by our Mr. B.A. Svensson, Assistant Plant Manager, to Mr. James Belanger, NRC Operations Center, at 1450 hours on October 4, 1983. At that time we reported that the Steam Jet Air Ejector Monitor (SRA-2905) was determined to be inoperable and the eight-hour grab sample was not completed within the required time frame.

As required by Technical Specification 6.9.1.12, a followup report will be submitted within 14 days.

Sincerely,


W.G. Smith, Jr.
Plant Manager

/bab

cc: John E. Dolan
M.P. Alexich
R.F. Kroeger
H. Brugger
E. Swanson/N. DuBry, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee
INPO
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE (40 copies)
Dir., MIPC (4 copies)

8310120379 831004
PDR ADOCK 05000316
S PDR

OCT 6 1983
IE22 1/0