

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201
September 30, 1983
LOZ-83-0155

J. WILLIAMS, JR
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e) ITEM E-30
W.O. 57300, JOB E-5590, FILE NO. 956C, E-30

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on October 27, 1982 under the requirements of 10CFR50.55(e). Our last report was submitted on July 28, 1983.

To update our previous response, the procedure revision for cable termination is now scheduled for approval by October 15, 1983. The walkdown portion of procedure NEP-8.5 for the review of electrical separation of cables in essential panels has been completed. The documentation of the analysis of the interactions identified is complete. Engineering is currently reviewing these analyses for acceptability.

CG&E will also evaluate the failure to properly incorporate instructions and criteria in construction and inspection procedures to determine the need for corrective action in this area. A follow-up report will be submitted by December 31, 1983.

50-358

8310120383 B30930
PDR ADDCK 05000358
S PDR


OCT 6 1983
IE 27
1/1

Mr. J.G. Keppler
Regional Administrator
September 30, 1983
LOZ-83-0155
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By  J. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/sfr

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATTN: T.P. Gwynn
NRC Zimmer Project Inspector, Region III
ATTN: E. R. Schweibinz