

## LICENSEE EVENT REPORT

CONTROL BLOCK: 

1	2	3	4	5	6
---	---	---	---	---	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1
---	---

 M I D C C 2 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 

5
---

  
7 8 9 14 15 25 26 30 57 CAT 58  
LICENSEE CODE LICENSE NUMBER LICENSE TYPECON'T  

0	1
---	---

 REPORT SOURCE L 6 0 5 0 0 0 3 1 6 7 0 9 0 1 8 3 8 0 9 2 8 8 3 9  
7 8 60 61 68 69 74 75 80  
DOCKET NUMBER EVENT DATE REPORT DATE

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2
---	---

 DURING A CONTROLLED SHUTDOWN AT APPROXIMATELY 10E-8 POWER TAVG DECREASED BELOW THE  

0	3
---	---

 TECH SPEC MINIMUM OF 541 DEGREES F. ACTIONS WERE IMMEDIATELY TAKEN WHICH TERMINATED  

0	4
---	---

 THE COOLDOWN AT 535 DEGREES F. TEMPERATURE COULD NOT BE RETURNED TO >541 DEGREES F  

0	5
---	---

 WITHIN 15 MINUTES SO THE REACTOR TRIP BREAKERS WERE OPENED IN COMPLIANCE WITH THE  

0	6
---	---

 ACTION OF T.S. 3.1.1.5. NO PROBABLE CONSEQUENCES RESULTED. OCCURRENCES OF A  

0	7
---	---

 SIMILAR NATURE INCLUDE 50-316/78-10, 78-32, 78-92, 81-31, 82-66 AND 50-315/78-39,  

0	8
---	---

 80-18.  
7 8 9 80

0	9
---	---

 SYSTEM CODE R B 11 CAUSE CODE D 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
EVENT YEAR 8 3 17 LER/RO REPORT NUMBER 18 3 19 ACTION TAKEN G 18 Z 19 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD B 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26  
21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 40 41 42 43 44 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0
---	---

 OPERATORS HAD STABILIZED REACTOR POWER AT 10E-8 AMPS TO TAKE CRITICAL DATA JUST  

1	1
---	---

 PRIOR TO DRIVING THE CONTROL RODS COMPLETELY IN. REACTOR HEAT OUTPUT DURING THIS  

1	2
---	---

 TIME COULD NOT COMPENSATE FOR HEAT LOSS THROUGH TURBINE DRAINS AND MAIN FEEDPUMP  

1	3
---	---

 STEAM DEMAND. THE REQUIREMENT TO TAKE CRITICAL DATA HAS BEEN DELETED FROM THE  

1	4
---	---

 SHUTDOWN PROCEDURE.  
7 8 9 80

1	5
---	---

 FACILITY STATUS D 28 % POWER 0 0 5 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION ANNUNCIATION 32  
7 8 9 10 12 13 44 45 46 80  
ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80  
PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 11 12 13 80  
PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 11 12 80  
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 80  
PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 80  
NAME OF PREPARER D. M. DRAPER PHONE (616) 465-5901  
8310120445 830928  
PDR ADOCK 05000316  
S PDR  
NRC USE ONLY  
68 69 80