



Carolina Power & Light Company

Raleigh, N. C. 27602

Raleigh, North Carolina

February 14, 1984

COPY

FILE: Brunswick 12510D

SERIAL: NO-84-073

Mr. Charles Wakild
Regional Supervisor
North Carolina Division of Environmental Management
7525 Wrightsville Avenue
Wilmington, NC 28403

Dear Mr. Wakild:

Brunswick Steam Electric Plant
NPDES Permit No. NC0007064

During the period of January 16, 1984, to January 24, 1984, Unit 1 of the Brunswick Steam Electric Plant operated with one fine mesh screen in service. The screens were removed one at a time during this period to allow for repairs to the chlorine solution lines in the pump bays. The chlorine lines had frozen and cracked as a result of extremely cold temperatures on December 25.

Repairs were completed on January 24, 1984, and both fine mesh screens on Unit 1 were returned to service.

Should you have any questions concerning this report, please contact Mr. G. C. Dobbins, Jr., in Raleigh at (919) 836-6083.

Yours very truly,

ORIGINAL SIGNED BY

P. W. HOWE
P. W. Howe

Vice President

Brunswick Nuclear Project

BWS:ss

NO23-Y

cc: Mr. H. R. Denton ✓
Mr. J. P. O'Reilly

8402240101 840214
PDR ADDCK 05000325
S PDR

IE23
1/0