



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

February 17, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Byron Generating Station Units 1 and 2
Use of Penetrameter Shims During
Radiography
NRC Docket Nos. 50-454 and 50-455

Reference (a): August 15, 1983 letter from E. D. Swartz
to H. R. Denton.

Dear Mr. Denton:

This is to withdraw the request made in reference (a) for NRC approval for use of the Winter 1983 Addenda of the ASME Boiler and Pressure Vessel Code at Byron Station. Our review of radiographs indicates penetrameter shims were used where necessary to satisfy our existing Code commitment. The authorized Nuclear Inspector concurs in this assessment.

Please direct any questions regarding this matter to this office.

One signed original and fifteen copies of this letter are provided for NRC review.

Very truly yours,

T. R. Tramm
Nuclear Licensing Administrator

lm

8402240108 840217
PDR ADOCK 05000454
A PDR

Boo!
1/0

8162N