



Consumers
Power
Company

Donald B Miller, Jr
Site Manager
Midland Project

Midland Project: PO Box 1963, Midland, MI 48640 • (517) 631-8650

October 10, 1983

50-329

50-330

Mr. G. A. Hierzer
Bechtel Power Corporation
P O Box 2167
Midland, MI 48640

MIDLAND ENERGY CENTER GWO 7020
IMPLEMENTATION OF B&W SOM LETTER
File: M-1.0 UFI: 08*06*03 Serial: CSC-6935

The attached B&W Site Office Manager (SOM) letter no. 490 has been reviewed by CPCo. We request that Bechtel forward this information to B&W Construction Company.

Handwritten signature: D.B. Miller

DBM/TIJ/klp

Attachment

cc: WShearn
KFPulito

PRINCIPAL STAFF			
RA	ENF		
D/RA	SCS	3	
A/RA	PAO		
OPR	SLO		
ONMA	RC		
DRMSF			
DE			
ML			
OL	FILE		

8310170257 831010
PDR ADOCK 05000329
A PDR

OCT 13 1983

Babcock & Wilcox

a McDermott company

Utility Power Generation Division

October 4, 1983

3315 Old Forest Road
P.O. Box 1260
Lynchburg, Virginia 24505-1260
(804) 385-2000

SOM 490
12B60

Mr. D. B. Miller, Jr.
Site Manager
Consumers Power Company
Post Office Box 1963
Midland, Mi 48640

Subject: TORQUE WRENCH FOR REPLACEMENT OF CSA FLOW DISTRIBUTOR BOLTS

Dear Mr. Miller:

In reference to FCA 13/180, Rev. 01, Lynchburg Engineering offers the following:


A Snap-On Corporation Model TE-602L torque wrench is required. It has a dial readout in 10 ft-lb increments and a 0 to 600 ft-lb range.

FCA 13/180 will reflect this model number at final revision.

If you have questions, please advise.

Very truly yours,

THE BABCOCK & WILCOX COMPANY



I. D. Green
Site Operations Manager

IDG/REK/dl

CC: G. B. Slade
J. T. Walton
J. D. Phinney
D. F. Judd
R. C. Mason
J. S. Shively