

LMB



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

October 5, 1983


Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58/DPR-74
Docket Nos. 50-315 and 50-316

Dear Mr. Keppler:

Pursuant to the requirements of Appendix B, Part II, Nonradiological, Environmental Protection Plan, Section 3.2, a copy of the report to the Michigan Water Resources Commission notifying them of a failure to collect a 24-hour composite sample on September 17, 1983, is attached. This report is required by Amendment 54 to Facility Operating License No. DPR-58 and Amendment No. 40 to Facility Operating License No. DPR-74 dated May 6, 1982.

Sincerely,


W.G. Smith, Jr.
Plant Manager

/bab

cc: John E. Dolan
M.P. Alexich
R.F. Kroeger
H. Brugger
E. Swanson/N. DuBry, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee
INPO
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE (20 copies)
Dir., MIPC (2 copies)
Dir., Nuclear Reactor Regulation

8310170387 831005
PDR ADOCK 05000315
S PDR

OCT 13 1983

IE22 //



INDIANA & MICHIGAN ELECTRIC COMPANY

ONE SUMMIT SQUARE, P. O. BOX 60, FORT WAYNE IN. 46801
Telephone: (219) 425-2111

RICHARD C. MENGE
Vice President

September 22, 1983

William Marks
Technical Secretary
Michigan Water Resources Commission
Stevens T. Mason Building
P.O. Box 30028
Lansing, Michigan 48926


Re: Donald C. Cook Nuclear Plant
NPDES Permit No. MI 0005827

Dear Mr. Marks:

On September 17, 1983, when collecting the daily sample from the turbine room sump 24-hour composite sampler, the sampler was found to be empty. A grab sample of the sump effluent was made for reporting purposes. Investigation revealed a stuck valve.

The pump valve was repaired and the compositor was returned to service.


Very truly yours,


R. C. Menge
Vice President

RCM/be

cc: W. G. Smith

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


R. C. Menge

bc: R. W. Jurgensen
T. A. Kriesel
J. A. Wojcik
R. W. Reeves/C. E. Hawk
E. L. Kropp
R. E. Zahler