

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

2 88 24
February 10, 1984

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303


Re: RII:RCD
McGuire Nuclear Station
Docket Nos. 50-369, 50-370
IE Bulletin 83-08

Dear Mr. O'Reilly:

This letter is in response to IE Bulletin 83-08 which concerned electrical circuit breakers with an undervoltage trip feature in use in safety-related applications other than the reactor trip system. A review of plant records has shown that no Westinghouse type DB, Westinghouse type DS or General Electric type AK-2 circuit breakers are used in any safety-related applications at McGuire Nuclear Station.

I declare under penalty of perjury that the statements set forth herein are true and correct to the best of my knowledge.

Very truly yours,



Hal B. Tucker

WHM/plp

cc: Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. W. T. Orders
NRC Senior Resident Inspector
McGuire Nuclear Station

8402280177 840210
PDR ADUCK 05000369
PDR
Q

484
1/0