

1E 27
1/1

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

February 13, 1984
ANPP-28840-BSK/TRB

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 84-01
A 50.55(e) Potentially Reportable Deficiency Relating to the
Startup Test Program apparently does not adequately track
retests of preoperational tests
File: 84-019-026; D.4.33.2


Reference: Telephone Conversation between P. Narbut and J. Cook on
January 20, 1984.

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that a
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by April 9, 1984, at which time a complete report will be
submitted.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President, Nuclear
ANPP Project Director

EEVB/TRB:db
Attachment

cc: See Page Two

8402280301 840213
PDR ADOCK 05000528
S PDR

1984 FEB 21 PM 3:24

RECEIVED
MTC

Mr. T. W. Bishop
DER 84-01
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
W. E. Ide
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
J. Vorees
J. R. Bynum
P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 84-01
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1

I. POTENTIAL PROBLEM

The Startup Test Program does not adequately track retests of preoperational tests after work is performed on a structure, system, or component to insure satisfactory performance. A documented program has not been implemented to track preoperational retests in the Startup program. Outstanding preoperational retests during/after system turnover to Operations are also not adequately controlled by procedures.

II. APPROACH TO AND STATUS OF PROPOSED RESOLUTION

APS Startup is presently reviewing the identified deficiencies. Any necessary changes identified during the evaluation will be implemented in the Startup Program.

III. PROJECTED COMPLETION OF CORRETIVE ACTION AND SUBMITTAL OF THE FINAL REPORT REPORT

Evaluation of this condition and submittal of the Final Report is Forecast to be completed by April 9, 1984