

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Beaver Valley Power Station, Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 0 0 0 0 0				PAGE (3) 1 OF 1											
TITLE (4) Manual Safety Injection caused by personnel error																									
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)															
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER (5)												
0	1	2	5	8	4	8	4	0	0	2	0	0	0	2	2	3	8	4	N/A	0	5	0	0	0	0
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)																							
1		20.402(b)				20.405(c)				X 50.73(a)(2)(iv)				73.71(b)											
POWER LEVEL (10)		20.405(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)											
1 0 0		20.405(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)											
		20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(vii)(A)															
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(vii)(B)															
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)															
LICENSEE CONTACT FOR THIS LER (12)																									
NAME										TELEPHONE NUMBER															
Robert J. Druga, Chief Engineer										AREA CODE 4 1 1 2 6 4 3 1 1 2 6 4															
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS											
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR											
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO															

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 0305 hours, during the performance of Maintenance Surveillance Procedure 1.04 (Reactor Protection Logic System Train "A" Bi-Monthly Test), the reactor operator mistakenly depressed the train "B" manual safety injection pushbutton instead of the train "B" safety injection reset pushbutton. These pushbuttons are located adjacent to one another on the benchboard. This error resulted in a train "B" safety injection and a reactor trip. All safety equipment functioned properly and at the proper setpoints. Operations personnel followed the applicable emergency procedures and stabilized the plant in hot standby. Plastic covers will be installed over the manual safety injection pushbuttons during the next extended outage. Disciplinary action has been taken against the operator.

Safety injections to date: 17 operational, 2 pre-operational.

8402280366 840223
PDR ADOCK 05000334
S PDR

IE 22
11



Duquesne Light

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

February 23, 1984
NDISS1:2003

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 84-002


United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

In accordance with Appendix A, Beaver Valley Technical Specifications,
the following Licensee Event Report is submitted:

LER 84-002, 10CFR 50.73.a.2.IV, "Manual Initiation of an Engineered
Safety Feature".

Very truly yours,


Wm. S. Lacey
Station Superintendent

Attachment

IER2
1/1

U. S. NRC - Document Control Desk
February 23, 1984
ND1SS1:2003
Page two

cc: Director of Management & Program Analysis
United States Nuclear Regulatory Commission
Washington, D.C. 20555

C. A. Roteck, Ohio Edison

Director, Office of Inspection and Enforcement Headquarters
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Peter Tam, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D.C. 20555

W. Troskoski, Nuclear Regulatory Commission, BVPS Site Inspector

Mr. Alex Timme, CAPCO Nuclear Projects Coordinator, Toledo Edison

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

G. E. Muckle, Factory Mutual Engineering, Pittsburgh

Dr. Thomas E. Murley
Regional Administrator
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406