

Georgia Power Company  
Post Office Box 4545  
Atlanta, Georgia 30302  
Telephone 404 522-6060



## Vogle Project

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011

February 15, 1984

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II-Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

File: X7BG03-M41  
Log: GN-318

Reference: Vogle Electric Generating Plant - Units 1 and 2, 50-424, 50-425;  
Embed Plate Base Metal Failure, GN-294, dated 12/19/83

Attention: Mr. James P. O'Reilly

Gentlemen:

In the above referenced letter, Georgia Power Company committed to notify the NRC of the results of our evaluation by February 17, 1984. Georgia Power Company has completed its review and evaluation of the embed plate base metal failure event and has concluded that this is an isolated event that is not reportable pursuant to the requirements of 10 CFR 50.55 (e) and 10 CFR 21.

Even though the original event related to the separation of a non-safety related pipe support from its embed plate, Georgia Power Company investigated this event due to the potential that a similar situation could exist on safety related supports and embed plates. Based on a sampling of the installed plates and supports, this was concluded to be an isolated event and therefore not reportable.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

*D. O. Foster*  
D. O. Foster

DOF:gcs

xc: U.S. Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

OFFICIAL COPY  
DESIGNATED ORIGINAL  
Certified By *Key* 1/0

xc: R. J. Kelly	D. E. Dutton	J. A. Bailey	L. T. Gucwa
R. E. Conway	W. F. Sanders	O. Batum	M. Malcom
G. F. Head	R. H. Pinson	G. Bockhold	H. H. Gregory, III
C. W. Hayes	P. D. Rice	B. M. Guthrie	J. T. Beckham, Jr.
D. N. MacLemore	R. A. Thomas	E. D. Groover	J. L. Vota

9402280378 B40215  
PDR ADOCK 05000424  
S PDR