

UNIT SHUTDOWN AND POWER REDUCTIONS
REPORT MONTH AUGUST 1983

311

Doc # No. 50-272
Unit Name Salem No.2
Date Sept. 10, 1983
Telephone 609-935-6000
Extension 4455

Completed by L.K. Miller

No.	Date	Type 1	Duration Hours	Reason 2	Method of Shutting Down Reactor	License Event Report	System Code 4	Component Code 5	Cause and Corrective Action to Prevent Recurrence
83-074	8/08	F	197.6	B	1	---	HF	PUMPXX	Circulating Water Pump Motors
83-076	8/10	"	2.4	"	"	"	"	FILTER	Traveling Screens/ Trash Racks
83-078	8/11	"	133.0	"	"	"	IE	INSTRU	Canal Screens Nuclear Excore Nuclear Instrumenta.
83-080	8/17	"	4.1	"	"	"	HF	FILTER	Traveling Screens/ Trash Racks
83-082	8/17	"	12.5	"	"	"	"	"	Canal Screens
83-084	8/18	"	2.7	"	"	"	"	"	"
83-086	8/18	"	2.9	"	"	"	"	"	"
83-088	8/19	"	306.8	"	"	"	HA	GENERA	Generator Stator Trouble

1
F: Forced
S: Scheduled

2 Reason
A-Equipment Failure-explain
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & Licensing Exam
F-Administrative
G-Operational Error-explain
H-Other-explain

3 Method
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Continuation of
Previous Outage
5-Load Reduction
9-Other

4 Exhibit G
Instructions
for Preparation
of Data
Entry Sheets
for Licensee
Event Report
(LER) File
(NUREG 0161)

5 Exhibit 1
Salem as
Source

IE 24

8310180114 831010
PDR ADDCK 05000311
PDR



Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 08038

Salem Generating Station

September 20, 1983

Director, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

MONTHLY OPERATING REPORT
SALEM NO. 2
DOCKET NO. 50-311

The attached is a revision to the monthly operating report for Salem Unit No. 2 for the month of August 1983. The revision consists of the addition of a second page to the Unit Shutdowns and Power Reduction section of the report. This page was inadvertently omitted from the August report when it was issued.

Sincerely yours,

A handwritten signature in cursive script, appearing to read "J. M. Zupko, Jr.", written in dark ink.

J. M. Zupko, Jr.
General Manager -
Salem Operations

LKM:kl1

CC: Dr. Thomas E. Murley
Regional Administrator USNRC
Region I
631 Park Avenue
King of Prussia, PA 19405

Director, Office of Management
Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Enclosures
Page 4a
8-1-7.R4

IE 24

1/1