



Carolina Power & Light Company

FEB 20 1984

SERIAL: NLS-84-071

Director of Nuclear Reactor Regulation  
Attention: Mr. D. B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
United States Nuclear Regulatory Commission  
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2  
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62  
RESPONSE TO THE TECHNICAL EVALUATION REPORT OPEN ITEMS  
CONCERNING CONTROL OF HEAVY LOADS

Dear Mr. Vassallo:

In a letter dated February 3, 1984, Carolina Power & Light Company (CP&L) provided your staff with our responses to the open issues discussed in the draft Technical Evaluation Report (TER) concerning the Control of Heavy Loads at the Brunswick Steam Electric Plant (BSEP) Units 1 and 2.

A review of these responses has found a typographical error in our response to the open issue on TER page 15, Section 2.1.5 Item C.1. The first sentence in the response should be changed to read as follows:

The acceptance testing and maintenance program for the spent fuel cask yoke is in compliance with Section 5 of ANSI N14.6-1978; however, exception is taken to the visual inspection frequency of Section 5.3.7 due to infrequent usage.

The word "yoke" has been inserted following the word "cask". Carolina Power & Light Company apologizes for any inconvenience this may have caused.

Should you have any questions concerning this letter, please do not hesitate to contact a member of our Licensing Staff.

Yours very truly,

S. R. Zimmerman  
Manager

Nuclear Licensing Section

8402280537 840220  
PDR ADOCK 05000324  
P PDR

PPC/lcv (9515PPC)

cc: Mr. D. O. Myers (NRC-BSEP)  
Mr. J. P. O'Reilly (NRC-R11)  
Mr. M. Grotenhuis (NRC)

A033  
1/0