

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

October 21, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362
Correction to 14-Day Follow-Up Report
Licensee Event Report No. 83-073
San Onofre Nuclear Generating Station, Unit 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated October 17, 1983

The referenced letter provided the 14-Day Follow-Up Report and a copy of the Licensee Event Report (LER) form for a reportable occurrence involving the operability of the charging pumps. As was discussed with the Senior Resident Inspector on October 19, 1983, correction of the content of the referenced letter is required.

The third paragraph of the second page of the referenced letter describes the cause of the reported occurrence and indicates that although a revision to the Abnormal Valve Lineup Procedure SO23-0-36 had been issued, training in the revision had not been provided and, consequently, the Abnormal Valve Lineup section of Procedure SO23-0-13 had not been revised to refer to SO23-0-36. The Abnormal Valve Procedure, SO23-0-36, referred to is the original issue of the procedure on September 13, 1983, rather than a revision as was indicated. In addition, although our administrative processes can provide for a specified delay in the effectiveness of procedures until training has been accomplished, in this case, our administrative process was not implemented to provide for a specified delay in revision of SO23-0-13 until training was accomplished on SO23-0-36.

8311040022 831021
PDR ADOCK 05000362
S PDR


RECEIVED
OCT 24 1983

1/0 IE-22

October 21, 1983

If there are any questions concerning this correction, please contact me.

Sincerely,

A handwritten signature in dark ink, appearing to read "J. G. Haynes", with a stylized flourish at the end.

J. G. HAYNES
STATION MANAGER

cc: A.E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)