

Mailing Address

Alabama Power Company
660 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Fintridge Building

USNRG 103 NOV 25
ATLANTA, GEORGIA

03 NOV 25 P 1: 57

November 18, 1983



Alabama Power
the southern electric system

Docket Nos. 50-348
50-364

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region III, Suite 3100
101 Marietta Street N. W.
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

I.E. Bulletin 83-06, entitled "Nonconforming Materials Supplied By Tube-Line Corporation Facilities at Long Island City, New York; Houston, Texas; and Carol Stream, Illinois," requested each licensee to determine whether any Tube-Line supplied materials have been procured for use in safety related applications. In accordance with this request, Alabama Power Company has conducted a review of procurement documentation for the Farley Nuclear Plant - Units 1 and 2. As a result of this review, it was determined that no materials supplied directly by Tube-Line Corporation have been procured or utilized in either Unit 1 or 2 of Farley Nuclear Plant in safety related applications. In addition, Alabama Power Company contacted all vendors who may have included Tube-Line components in safety-related equipment sold to Alabama Power Company. These vendors have informed Alabama Power Company that based upon their evaluation, none of this equipment included Tube-Line components.

A total of approximately 690 manhours were expended in the preparation of this response.

If you have any questions, please advise.

Yours very truly,

8312050008 831118
PDR ADOCK 05000348
Q PDR

F. L. Clayton, Jr.
F. L. Clayton, Jr.

IE 11

110

FLCJr/RWS:lsh-D13

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge
Mr. S. A. Varga
Mr. E. A. Reeves
Mr. W. H. Bradford
NRC Document Control Desk

SWORN TO AND SUBSCRIBED BEFORE ME
THIS 18th DAY OF November 1983

Linda Humber
Notary Public

My Commission Expires: 1-10-87