

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE (717) 542-2181



Pennsylvania Power & Light Company

November 21, 1983

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-151/03L-0
ER 100450 FILE 841-23
PLA-1960

Docket No. 50-387
License No. NPF-14

Dear Dr. Murley:

Attached is Licensee Event Report No. 83-151/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that during routine operator rounds, it was noted that Reactor Building Zone I differential pressure was less than 0.25 inches vacuum water gauge. Limiting Condition for Operation (LCO) 3.6.5.1 was entered, the alternate Zone I exhaust fan was started and proper building differential pressure established within thirty minutes.

H.W. Keiser

LAK/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE 22
1/1