



AUG 26 1991

L-91-233  
10 CFR 50.36

U. S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555


Gentlemen:

Re: St. Lucie Unit 1 and 2  
Docket No. 50-335 and 50-389  
Special Report  
Date of Event: August 9, 1991  
Meteorological Instrumentation Out of Service

The attached Special Report is being transmitted pursuant to the requirements of St. Lucie Unit 1 and 2 Technical Specifications 3.3.3.4 and 6.9.2. The report provides notification that the St. Lucie meteorological station has been removed from service for greater than seven days. The report due date was inadvertently missed.

Should there be any questions on this information, please contact us.

Very truly yours,

  
D. A. Sager  
Vice President  
St. Lucie Plant

DAS/JJB/kw

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, St. Lucie Plant

DAS/PSL #507-91

IE22  
111

## ATTACHMENT

### NRC SPECIAL REPORT METEOROLOGICAL INSTRUMENTATION OUT OF SERVICE GREATER THAN 7 DAYS

On August 1, 1991 the entire St. Lucie site meteorological station was removed from service. The reason for placing the site meteorological station out of service was due to a planned plant modification to replace obsolete meteorological equipment. This modification entails new instrumentation, a new meteorological tower, and new communication equipment. The modifications and instrument calibration will be completed on or before 29 August, 1991, and the St. Lucie site meteorological station will be placed back in service by that time.

As required by Technical Specification 3.3.3.4, this Special Report is being submitted to notify the NRC that the St. Lucie site meteorological station has been removed from service for greater than 7 days. As a compensatory measure, all release of gaseous radioactive material from the radwaste gas decay tanks at both units was suspended. Additionally, communication checks have been made with the National Weather Service in West Palm Beach.