

RECEIVED
NRC

Southern California Edison Company

NOV 28 PM 12:15

SCE

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

REGION V

J. G. HAYNES
STATION MANAGER

TELEPHONE
(714) 492-7700

November 23, 1983

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Prompt Report
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to License Condition 2.G to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this submittal provides written confirmation of our notification to the NRC on November 23, 1983, of reportable occurrences associated with the fire protection program.

License Conditions 2.C.(14)a and 2.C(12)a of Operating Licenses NPF-10 and NPF-15, respectively, require that SCE maintain in effect and fully implement the Fire Protection Plan as delineated in the Fire Hazards Analysis (FHA). During a review of Nonconformance Reports (NCR's) and draft FHA license amendment documents, it was determined on November 22, 1983, that some of the deficiencies identified in the NCR's and license amendment documents may have violated the FHA. Our investigation into these NCR's and license amendment documents is continuing.

Licensee Event Report (LER) 83-127 (Docket No. 50-361) reported inoperable fire rated assemblies for which Technical Specification Limiting Condition for Operation (LCO) 3.7.9, Action Statement 'a', was invoked and satisfied. These inoperable fire rated assemblies were incorporated into six NCR's, and during our review of the NCR's and license amendment documents, described above, we determined that the six NCR's of LER 83-127 may also be in violation of the FHA.

8312060055 831123
PDR ADOCK 05000361
S PDR

1/0 10-22

Mr. J. B. Martin


-2-

November 23, 1983

SCE believes that it is not the intent of License Condition 2.G to require the reporting of incidents such as these and are seeking clarification from NRR. A 14-Day Follow-Up Report will be submitted by December 7, 1983.

If you have any questions regarding the above, please so advise.

Sincerely,

A handwritten signature in dark ink, appearing to read "J. B. Martin", is written below the word "Sincerely,".

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)