

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C | A | D | C | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

CONT

01 | REPORT SOURCE | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 5 | 7 | 1 | 0 | 2 | 1 | 8 | 3 | 6 | 1 | 1 | 2 | 1 | 8 | 3 | 6 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Before fuel load, the Steam Generator Blowdown Tank Vent Gross Activity Monitor
03 | (RM-27) failed downscale while in service. The actions required in Technical
04 | Specification 3.3.3.10 were taken. No radioactive effluents were released since
05 | no fuel had been in the core. This event has in no way affected the public's
06 | health and safety. Reportable under Technical Specification Section 6.9.1.13.b.
07 |
08 |

09 | M | C | 11 | E | 12 | F | 13 | I | N | S | T | R | U | 14 | Y | 15 | Z | 16 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

17 | LER/RO REPORT NUMBER | 8 | 3 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 |
21 | 8 | 3 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 |

18 | ACTION TAKEN | 19 | FUTURE ACTION | 20 | EFFECT ON PLANT | 21 | SHUTDOWN METHOD | 22 | HOURS | 23 | ATTACHMENT SUBMITTED | 24 | NRC-1 FORM SUB. | 25 | PRIME COM. SUPPLIER | 26 | COMPONENT MANUFACTURE |
33 | A | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | RM-27 failed as the result of a random failure of the U-2 bistable multivibrator.
11 | The bistable was replaced, a functional test was performed, and the unit was
12 | returned to service.
13 |
14 |

15 | B | 28 | 0 | 0 | 0 | 29 | NA | 30 | A | 31 | During normal operation | 32 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

18 | 0 | 0 | 0 | 40 | NA | 41 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

19 | Z | 42 | NA | 43 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

20 | N | 44 | NA | 45 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

NAME OF PREPARER William J. Kelly

PHONE 805-595-7351

RECEIVED
NRC

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET, SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS
NUCLEAR POWER GENERATION

REGION VISE

November 21, 1983

Mr. John B. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76
Diablo Canyon Unit 1
Licensee Event Report 83-025/03L-0
Inoperable Gross Activity Monitor

Dear Mr. Martin:

Pursuant to Section 6.9.1.13.b of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 operating license, the enclosed Licensee Event Report is submitted concerning an Inoperable Steam Generator Blowdown Tank Vent Gross Activity Monitor (RM-27).

This event has in no way affected the public's health and safety.

Sincerely,



Enclosure

cc: G. W. Knighton

Director, Office of Management Information
and Program Control

Service List

11 IE-11