

TABLE 3.7.4

PRIMARY CONTAINMENT TESTABLE ISOLATION VALVES

<u>Pen No.</u>		<u>Notes</u>
22	A0-2969A (Unit #2); A0-3969A (Unit #3) Check Valve	1,2,4,5 1,2,4,5
23	M0-2373 (Unit #2); M0-3373 (Unit #3)	1,2,4,5
24	M0-2374 (Unit #2); M0-3374 (Unit #3)	1,2,4,5
25, 205B	A0-2502A (Unit #2); A0-3502A (Unit #3) A0-2505 (Unit #2); A0-3505 (Unit #3) A0-2519 (Unit #2); A0-3519 (Unit #3) A0-2520 (Unit #2); A0-3520 (Unit #3) A0-2521A (Unit #2); A0-3521A (Unit #3) A0-2521B (Unit #2); A0-3521B (Unit #3) A0-2523 (Unit #2); A0-3523 (Unit #3) Check Valve 9-26A; Two Check Valves	1,2,4,5,9,12 1,2,4,5 1,2,4,5 1,2,4,5,9,12 1,2,4,5 1,2,4,5,9,12 1,2,4,5 1,2,4,5
26	A0-2506 (Unit #2); A0-3506 (Unit #3) A0-2507 (Unit #2); A0-3507 (Unit #3) A0-2509 (Unit #2); A0-3509 (Unit #3) A0-2510 (Unit #2); A0-3510 (Unit #3) A0-4235 (Unit #2); A0-5235 (Unit #3) SV-2671G (Unit #2); SV-3671G (Unit #3) SV-2978G (Unit #2); SV-3978G (Unit #3) SV-4960B (Unit #2); SV-5960B (Unit #3) SV-4961B (Unit #2); SV-5961B (Unit #3) SV-4966B (Unit #2); SV-5966B (Unit #3) SV-8100 (Unit #2); SV-9100 (Unit #3) SV-8101 (Unit #2); SV-9101 (Unit #3)	1,2,4,5,9,12 1,2,4,5 1,2,4,5,9,11 1,2,4,5 1,2,4,5 1,2,4,5 1,2,4,5 1,2,4,5 1,2,4,5 1,2,4,5 1,2,4,5
32C, D	ILRT System Two Globe Valves	1,2,4,5,13
35E to G	TIP Ball Valves TIP Shear Valves	1,2,4,5 19
35C	SV-109; Check Valve	1,2,4,5
37A to D	CRD Insert; HCU	18
38	CV-3-32A; CV-3-32B; CV-3-33 CV-3-35A; CV-3-35B; CV-3-36 CRD Withdrawal; HCU	1,2,4,5 1,2,4,5 18
39A	M0-10-31B M0-10-26B SV-4949B (Unit #2); SV-5949B (Unit #3) Check Valve	1,2,4,5,9,10 1,2,4,5 1,2,4,5 1,2,4,5
39B	M0-10-31A M0-10-26A SV-4949A (Unit #2); SV-5949A (Unit #3) Check Valve	1,2,4,5,9,10 1,2,4,5 1,2,4,5 1,2,4,5